



Ref. Certif. No.

CN49620

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

ATSE

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province,
P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:8kV(main circuit),2.5kV(control circuit);Ui:800V(main
circuit),400V(control
circuit);Ue:AC400V;Ie:16A,20A,25A,32A,40A,50A,63A,80A,100A,125A;
Utilization category:AC-33B;Icm:52.5kA(Type L),73.5kA(Type
M);Icn:25kA(Type L),35kA(Type M); Class CB;Method of controlling:
ATSE,RTSE; 3P, 4P;

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGQ1N-125L/3,TGQ1N-125M/3,TGQ1N-125L/4,TGQ1N-125M/4;

Additional information (if necessary may also be
reported on page 2)

A sample of the product was tested and found
to be in conformity with

IEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in conjunction with
IEC 60947-1:2007 (5th Edition) + AMD 1:2010

As shown in the Test Report Ref. No. which
forms part of this Certificate

(2019)FQIIDQ-0657

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>



Date: Apr.16,2020

Signature:

陆梅

Lu Mei

CB 0056389