



**CHINA QUALITY CERTIFICATION CENTRE**  
**CERTIFICATE OF CONFORMITY**

**Certificate No.: CE200306006691**

**Product**

Automatic Transfer Switching Equipment

**Applicant**

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

**Type/Model**

TGQ1N-800L/3,TGQ1N-800M/3,  
TGQ1N-800L/4,TGQ1N-800M/4;

**Technical data**

Ui:800V(main circuit), 400V(auxiliary circuit, control circuit);  
Uimp:8kV(main circuit), 2.5kV(auxiliary circuit, control circuit);  
Ue:AC400V;Ie: 630A, 700A, 800A;Utilization  
Category:AC-33B;Icn: Type L:50kA, Type M:70kA; Icm(peak  
value): Type L:105kA, Type M:154kA;ATSE Class:CB;Transfer  
mode:ATSE, RTSE;Poles:3P, 4P.

This is to certify that, on the basis of the tests undertaken as per Report No.  
03601-A-19D0064-S, the submitted sample(s) of the above item complies with:

**EN 60947-6-1:2005 + A1:2014**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

**Valid from:** Apr.16,2020

**Valid until:** Apr.16,2023

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>