



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006827

Product

Automatic Transfer Switching Equipment

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGQ1N-400L/3,TGQ1N-400L/4,TGQ1N-400M/3,TGQ1N-
400M/4,TGQ1N-630L/3,TGQ1N-630L/4,TGQ1N-630M/3,T
GQ1N-630M/4;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-19D0061-S, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jun.11,2020

Valid until: Jun.11,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE200306006827

TGQ1N-400L/3,TGQ1N-400L/4,TGQ1N-400M/3,TGQ1N-400M/4,
TGQ1N-630L/3,TGQ1N-630L/4,TGQ1N-630M/3,TGQ1N-630M/4;
Ui:800V(main circuit);400V(control and auxiliary circuits);
Uimp:8kV(main circuit);2.5kV(control and auxiliary circuits);
Ue:AC400V;
Ie: 250A,315A,350A,400A(with TGM1N-400L,TGM1N-400M Circuit-breaker),
400A,450A,500A,630A(with TGM1N-630L,TGM1N-630M Circuit-breaker);
Utilization Category:AC-33B;
Icn: Type L:50kA, Type M: 70kA;
Icm(peak value): Type L:105kA, Type M:154kA;
Class of equipment: CB;
Method of controlling:
RTSE(only intelligent type with communication controller),ATSE;
3P, 4P.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>